

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WEST DAVIESS COUNTY )  
WATER DISTRICT FOR A DEVIATION FROM )  
807 KAR 5:066, SECTION 5(4) REGARDING ) CASE NO. 10397  
WATER STORAGE )

O R D E R

By letter received September 23, 1988, West Daviess County Water District ("West Daviess") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a utility to provide water storage to insure a minimum of one day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. West Daviess's current water storage capacity is 650,000 gallons.
2. West Daviess's average daily water usage including unaccounted-for-water is 1,002,974 gallons.
3. Because of the time needed to plan, finance and implement a program to increase its water storage facilities, West Daviess should be granted a deviation from 807 KAR 5:066, Section 5(4) until February 1, 1992 to bring it within compliance of the Commission's water storage requirements.

IT IS THEREFORE ORDERED that:


1. West Daviess be and it hereby is granted a deviation from 807 KAR 5:066, Section 5(4) until February 1, 1992.

2. West Daviess shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 21st day of December, 1988.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

\_\_\_\_\_  
Executive Director